

TEST REPORT

No. : SHIN2409002251CM01_EN

Date : 2024-10-29

Page: 1 of 3

Scan to see the report



SHIN2409002251CM01
Verification:
check.sgsonline.com.cn

CUSTOMER NAME: SHANGHAI INTCO INDUSTRIES CO.,LTD.
ADDRESS: NO.1299 HUBIN ROAD, FENG XIAN DISTRICT, SHANGHAI 201417 P
R CHINA

Sample Name : SPC WALL PANEL

Product Specification : 4mm

Above information and sample(s) was/were submitted and confirmed by the client. SGS, however, assumes no responsibility to verify the accuracy, adequacy and completeness of the sample information provided by client.

Date of Receipt : 2024-09-14
Testing Period : 2024-09-14 ~ 2024-10-10
Test result(s) : For further details, please refer to the following page(s)
(Unless otherwise stated the results shown in this test report refer only to the sample(s) tested)

Signed for
SGS-CSTC Standards Technical
Services (Shanghai) Co., Ltd..

Xander Yang

Xander Yang
Authorized signatory



Unless otherwise agreed in writing, this document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at <https://www.sgs.com/en/Terms-and-Conditions>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated the results shown in this test report refer only to the sample(s) tested and such sample(s) are retained for 30 days only.

Attention: To check the authenticity of testing /inspection report & certificate, please contact us at telephone: (86-755) 8307 1443, or email: CN.Doccheck@sgs.com

No.69, Block 1159, East Kang Qiao Road, Pudong District, Shanghai, China. 201319

中国·上海·浦东康桥东路1159弄69号 邮编: 201319

t(86-21) 61196300 www.sgs.com.cn

t(86-21) 61196300 sgs.china@sgs.com

TEST REPORT

No. : SHIN2409002251CM01_EN

Date : 2024-10-29


Page: 2 of 3

Summary of Results:

No.	Test Item	Test Method	Result	Conclusion
1	Dimensional Stability and Curling after Exposure to Heat	With Reference to EN ISO 23999:2021	See Result	N/A

Note: Pass : Meet the requirements;
 Fail : Does not meet the requirements;
 N/A : Not Apply to the judgment.

Original Sample Photo(s):



Unless otherwise agreed in writing, this document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at <https://www.sgs.com/en/Terms-and-Conditions>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated the results shown in this test report refer only to the sample(s) tested and such sample(s) are retained for 30 days only.
 Attention: To check the authenticity of testing /inspection report & certificate, please contact us at telephone: (86-755) 8307 1443, or email: CN.Doccheck@sgs.com
 No.69, Block 1159, East Kang Qiao Road, Pudong District, Shanghai, China. 201319
 t(86-21) 61196300 www.sgs.com.cn
 f(86-21) 61196300 sgs.china@sgs.com
 中国·上海·浦东康桥东路1159弄69号 邮编: 201319

TEST REPORT

No. : SHIN2409002251CM01_EN

Date : 2024-10-29

Page: 3 of 3

Test Item: Dimensional Stability and Curling after Exposure to Heat

Test Method: With Reference to EN ISO 23999:2021

Test Condition:

Specimen: 600mm×300mm×4.6mm, 3pcs

Heating Temperature: 80°C

Heating Time: 6h

Lab Environmental Condition: (23±2)°C, (50±5)%RH

Test Result:

Test Item		Test Result	
Dimensional Stability and Curling after Exposure to Heat	Dimensional Change (%)	Manufacturing Direction	Average Value: 0.00
		Across-manufacturing Direction	Average Value: 0.00
	Curling (mm)	0.5	

Note: Negative values indicate shrinkage, and positive values indicate expansion.

The test report shall only be used for clients' scientific research, teaching, internal quality control, product research and development, etc... and just for internal reference.

*****End of report*****



Unless otherwise agreed in writing, this document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at <https://www.sgs.com/en/Terms-and-Conditions>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated the results shown in this test report refer only to the sample(s) tested and such sample(s) are retained for 30 days only.

Attention: To check the authenticity of testing /inspection report & certificate, please contact us at telephone: (86-755) 8307 1443, or email: CN.Doccheck@sgs.com

SGS-CSTC Inspection & Testing Services (Shanghai) Co., Ltd.
Commercial Consultants & Technical Services

No.69, Block 1159, East Kang Qiao Road, Pudong District, Shanghai, China. 201319
中国·上海·浦东康桥东路1159弄69号 邮编:201319

t(86-21) 61196300 www.sgsgroup.com.cn
t(86-21) 61196300 sgs.china@sgs.com