

LU AN INTCO INDUSTRIES CO., LTD

TEST REPORT

SCOPE OF WORK

WPC DECKING

REPORT NUMBER

240703009SHF-001

TEST DATE(S)

2024-07-03 - 2024-07-16

ORIGINAL ISSUE DATE

2024-07-16

PAGES


5

DOCUMENT CONTROL NUMBER

LFT-APAC-SHF-OP-10I(February 1, 2024)

© 2024 INTERTEK

Intertek Testing Services Shenzhen Ltd. Shanghai Fengxian Branch



Test Report

Statement

- 1.This report is invalid without company's special seal for testing on the assigned page.
- 2.This report is invalid without an authorized person's signature.
- 3.This report is invalid if altered.
- 4.Only the Client is authorized to permit copying or distribution of this report and then only in its entirety. Don't copy this report in partial without any official approval in written by our company. This report is invalid without re-stamping the special seal for testing in copying report.
- 5.This report is for the exclusive use of Intertek's Client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this report. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test results in this report are relevant only to the sample(s) tested. This report by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.
- 6.Except for the obligation, responsibility and liability (if any) for the appropriateness and professionalism of afore-mentioned testing itself within the scope and amount of the testing fee received, Intertek does not and will not accept any other obligation or liability.
- 7.If the Client has any questions about the test results, Intertek B&C should be informed within the storage period of the samples. The sample storage period ends 5 working days after the official report issue date. Samples of certification program are retained for the period required by the certification rules. The samples storage period shall be calculated according to the issue date of the original report in the case of quoting results and modifying reports.
- 8.Intertek B&C will service this report for the entire test record retention period. The test record retention period ends 6 years after this report original issue date. The test record retention period for certification program is 10 years. Test records and other pertinent project documentation will be retained for the entire test record retention period.
- 9.The report was digital signed by Shang Hai, Intertek Group plc, please using Adobe Acrobat Reader to verify the authenticity.



Test Report

Original Issue Date: 2024-07-16

Intertek Report No. 240703009SHF-001

Applicant: LU AN INTOCO INDUSTRIES CO., LTD
Address: Yufeng Road, High-tech Industrial Development Zone Lu'an, Anhui
Attn: Juming Hu
Manufacturer: LU AN INTOCO INDUSTRIES CO., LTD
Address: Yufeng Road, High-tech Industrial Development Zone Lu'an, Anhui
Test Type: Performance test, samples provided by the applicant.

Product Information

Product Name	Model	Specification
WPC DECKING	/	/
Sample ID	Sample Amount	Sample Received Date
S240703009SHF.001	64 pcs	2024-06-27
Sample Description		
149mm×24mm		

Test Methods And Standards

Test Standard	EN 15534-1:2014+A1:2017 Section 6.2 ISO 1183-1:2019 Method A
Specification Standard	/
Test Conclusion	The samples were tested according to the above standards, and the results are shown in the following page.

Note:

1.This report does not involve sampling. The report only reflects conformity of the tested items of the samples provided by the testing applicant. Representativeness and authenticity of the submitted samples are responsibilities of the testing applicant.

Report Authorized

Sally Xie
Name: Sally Xie
Title: Reviewer

Erin Huang
Name: Erin Huang
Title: Project Engineer



Test Report

Original Issue Date: 2024-07-16

Intertek Report No. 240703009SHF-001

Test Items, Method and Results:

Test Item: Density

Condition: 96 hours at a temperature of 23±2°C and relative humidity of 50±5%

Test Item	Test Method	Test Result
Density	EN 15534-1:2014+A1:2017 Section 6.2 ISO 1183-1:2019 Method A	1.287 g/cm ³



Test Report

Original Issue Date: 2024-07-16

Intertek Report No. 240703009SHF-001

Appendix A: Sample Received Photo



Front view & Back view



Section view

Revision:

NO.	Date	Changes
240703009SHF-001	2024-07-16	First issue

